

## GENERAL HOSPITAL, REWARI

## WATER TESTING REPORT

MO/GH/Rewari/2020/084

Dated: 23/01/2020

To,

The President  
Rao Khem Chand Vidya  
Vihar Shiksha Samiti  
Brahmputra Ashram (Rewari)

Sub: Testing water sample of Bacteriology

Reference of your office letter No. RK&VV / 386 date 20/01/2020  
 on the subject cited above. The water sample report is as under:-

S.No.	Name of Place	Report
1	Rao Khem Chand Vidya Vihar	The probable coli form count is <u>2</u> per 100 ml of water, hence the water sample is <u>Fit</u> for human consumption
2	Rao Khem Chand College of Harmony	The probable coli form count is <u>2</u> per 100 ml of water, hence the water sample is <u>Fit</u> for human consumption
3	Rao Khem Chand College of Education	The probable coli form count is <u>3</u> per 100 ml of water, hence the water sample is <u>Fit</u> for human consumption
4	Rao Khem Chand Nursing College	The probable coli form count is <u>2</u> per 100 ml of water, hence the water sample is <u>Fit</u> for human consumption

*for M*  
 Microbiologist  
 Civil Hospital  
 Rewari

*Reenu*  
 Chief Technical Officer  
 Civil Hospital  
 Rewari